



YOUR GOALS. OUR MISSION.

ETSA-G1701

February 9, 2018

[info@theesa.org](mailto:info@theesa.org)

Authority Commissioners  
Eatontown Sewerage Authority  
Municipal Building  
47 Broad Street  
Eatontown, NJ 07724

**Re: Engineer's Status Report – January 2018**

Dear Commissioners:

Enclosed herein is my report on project status and issues for the month of November.

The following is the status of Capital Projects in progress:

1. **Brookwood Pump Station Upgrades**: Construction of the pump station in accordance with the plans is essentially complete. The contractor, T.R. Weniger, installed the generator and completed the associated electrical work. The pumps have been tested with the generator and are now back up and running. We have forwarded a preliminary punch-list to the contractor. We expect the next payment will be a final payment once all punch-list items are completed.
2. **Authority Garage Parking Lot Paving**: All work has been completed. T&M Associates is working with the contractor to prepare the final close out documents.
3. **Bidding Documents for Emergency Contracts**: We received bids for the various emergency contracts. Recommendation of award letters will be forwarded under separate cover.
4. **Lining of ACP Sewers**: We have begun discussions regarding lining all ACP sewers. Given the extent and quantity of these sewers, we recommend further discussion with the Board to determine how we should proceed.

During the reporting period, the following development project related work was performed:

1. **Fort Monmouth**: Regarding the Howard Commons site, Mid Atlantic Engineering Partners is taking over the project. T&M provided them with various sewer plans and plans for the Authority's Eaton Crest Pump Station in early August 2017. At this time, we continue to await a plan from Mid Atlantic for sewerage of the Howard Commons site. **No change.**



*Le: Authority Commissioners  
Eatontown Sewerage Authority*

*Re: Engineer's Status Report – January 2018*

2. **Monmouth Mall**: Langan Engineering has sent a site plan application package for the proposed redevelopment of the Monmouth Mall. I have seen the plans but no formal application has been made to the Sewerage Authority.

Projects reviewed and awaiting resubmittals:

1. **Beechwood Townhomes (Block 401, Lot 19)**: First Engineering Review letter issued July 7, 2016. T&M is awaiting a revised submittal for review.
2. **Commercial Plaza 35, LLC (Eatontown Shopping Center-Block 3801, Lots 21 and 22)**: Second engineering review letter issued on August 25, 2014. Comments remain to be addressed.
3. **Quick Chek (Block 2302, Lot 1)**: First Engineering Review letter issued December 23, 2014. Comments remain to be addressed.

Projects approved and awaiting construction or under construction:

1. **219 Tinton Avenue**: T&M issued a final engineering approval letter on May 4, 2017 for this development application which includes demolition of an existing home and construction of 3 new single-family homes on Tinton Avenue.
2. **CVS Pharmacy**: Upon T&M's engineering review of the resubmittal for the construction of the new CVS Pharmacy, it was determined that the applicant has met the engineering requirements set forth in the ESA Rules and Regulations and that all engineering items have been satisfied. A final engineering approval letter for construction of a new CVS Pharmacy at the intersection of Route 35 and Tinton Avenue was issued December 14, 2017, which also explained fees that were due prior to construction. An updated package was received by our office for this project on January 5, 2018.
3. **Lidl Grocery Store**: This project consists of a proposed Lidl Grocery Store which will be located on Route 35 just south of the Lowes site. T&M coordinated with the applicant to resolve remaining issues regarding the grease interceptor and a final engineering approval letter was issued July 6, 2017.
4. **176 Broad Street**: The applicant for the project, which consists of the demolition of one (1) home and the construction of two (2) single-family homes on Lots 12.01 and 12.02 in Block 1002, submitted revised plans for review in June 2017. T&M reviewed the resubmitted documents and issued a final engineering review letter dated July 5, 2017.



ETSA-G1701  
February 9, 2018  
Page 3

**Le: Authority Commissioners  
Eatontown Sewerage Authority**

**Re: Engineer's Status Report – January 2018**

If you have any further questions, please do not hesitate to contact me.

Very truly yours,

CHRISTINE A. BALLARD, P.E.  
EATONTOWN SEWERAGE AUTHORITY  
ENGINEER

CAB:scb

cc: Theodore Lewis, Executive Director  
Richard Johnson, Superintendent  
John Bonello, Esq., Authority Attorney

G:\Projects\ETSA\G1701\Correspondence\Status Report\_January 2018.docx